

0013



State of Utah
DEPARTMENT OF NATURAL RESOURCES
DIVISION OF OIL, GAS AND MINING

Michael O. Leavitt
Governor

Kathleen Clarke
Executive Director

Lowell P. Braxton
Division Director

1594 West North Temple, Suite 1210
PO Box 145801
Salt Lake City, Utah 84114-5801
801-538-5340
801-359-3940 (Fax)
801-538-7223 (TDD)

April 16, 2002

TO: Internal File

THRU: Daron R. Haddock, Permit Supervisor *DRH*

FROM: Gregg A. Galecki, Reclamation Hydrologist III *GAG*

RE: 2001 Fourth Quarter Water Monitoring, Savage Industries, Inc., Savage Coal Terminal, C/007/022-WQ01-4

1. Was data submitted for all of the MRP required sites? YES [x] NO []

Identify sites not monitored and reason why, if known:

2. On what date does the MRP require a five-year re-sampling of baseline water data.

See Technical Directive 004 for baseline resampling requirements. Consider the five-year baseline resubmittal when responding to question one above. Indicate if the MRP dose not have such a requirement.

Re-sampling due date Not Required

3. Were all required parameters reported for each site? YES [x] NO []

Comments, including identity of monitoring site:

Both UPDES and all other water monitoring sites were reported for the 4th quarter 2001.

4. Were irregularities found in the data?

YES [x] NO []

Comments, including identity of monitoring sites:

Well CV-1-W, the only non-UPDES water monitoring site, showed irregularities in the submitted lab data. The Ionic balance was – 7%, pH was an all time low of 6.34, and the Chloride, Sulfate, and Total Dissolved Solids values all illustrated historically high values. These values will continue to be monitored in the future to observe any trends.

5. Were DMR forms submitted for all required sites?

Identify sites and months not monitored:

1st month, YES [x] NO []

2nd month, YES [x] NO []

3rd month, YES [x] NO []

6. Were all required DMR parameters reported?

YES [x] NO []

Comments, including identity of monitoring sites:

CV-15-W recorded 'No Discharge.'

7. Were irregularities found in the DMR data?

YES [] NO [x]

Comments, including identity of monitoring sites:

CV-15-W recorded 'No Discharge.'

8. Based on your review, what further actions, if any, do you recommend?

No further action is necessary for the 2001 Fourth Quarter Water Monitoring data.